

From: USRB
Sent: Tuesday, October 10, 2017 9:10 PM
To: SED-Gas Section-South; SED-Gas Section-North; TerKeurst, Charlotte; Palmer, Leslie L.; SED-Electric Safety and Reliability Branch - North; SED-Electric Safety and Reliability Branch - South
Subject: FW: Electric Safety Incident Reported- PG&E Incident No: 171010-8558

Follow Up Flag: Flag for follow up

Flag Status: Completed

From: webmaster@cpuc.ca.gov
Sent: Tuesday, October 10, 2017 9:10:28 PM (UTC-08:00) Pacific Time (US & Canada)
To: USRB
Cc: CLF8@pge.com
Subject: Electric Safety Incident Reported- PG&E Incident No: 171010-8558

The Following information regarding this incident has been reported:

Reporting Date: 10/10/2017 9:08:09 PM
Incident Date: 10/8/2017 @ 10:00 p.m.
Reported By: Charles Filmer, Compliance specialist
Utility Name: PG&E
Phone Number: (530)902-5685
Email Address: CLF8@pge.com

Incident Location: [REDACTED] Kenwood, Sonoma

Reasons For Reporting:

- Fatalities? No (Utility: , Others:)
- Names of Fatalities:
- Injuries? (Utility: , Others:)
- Names of Injured:
- Damage? Yes (Utility: , Others:)
- Interruption? (Total Customers: , Total Hours:)
- Operator Judgement? No
- Media Coverage? No

Cause of Incident: Falling Tree (Other Cause:)

Agencies on Scene: Fire,

Facilities Affected:

- Utilities Facilities: [REDACTED]
- Voltage (KV): [REDACTED]
- Customer's Facilities:

DigIn Information:

- Excavator Name:
- Contact:
- Phone: (____) ____ - ____

Incident Recovery:

- On Scene Date & Time: @ 00:00 a.m.
- Service Restored: @ 00:00 a.m.

Summary: This afternoon, 10 October 2017, in Kenwood, Sonoma County, PG&E identified a broken tree and wire down on the [REDACTED] at [REDACTED]. An approximately 60-foot eucalyptus tree that was rooted approximately 50 feet from the lines had fallen, taking down all three primary conductors to the ground. This information is preliminary and PG&E is fully cooperating with Cal Fire.