



December 13th,2024

Mr. Fadi Daye, P.E.
Program and Project Supervisor
Electric Safety and Reliability Branch
Safety and Enforcement Division
California Public Utilities Commission
505 Van Ness Avenue
San Francisco, CA 94102-3298

Subject: 2024 SDG&E Response to CPUC Metro District Transmission Audit

Dear Mr. Daye:

San Diego Gas & Electric (SDG&E) appreciates the time Calvin Choi of the Electric Safety and Reliability Branch of the California Public Utilities Commission (CPUC) spent in the field September 16-20, 2024, in SDG&E's Metro District inspecting transmission structures and subsequently review inspection and maintenance records. The table below identifies findings Mr. Choi noted during fielding and review of records, and the corrective measures SDG&E took to remedy these findings.

CPUC Comment	SDGE Comment
SDG&E's records indicated that from 2020 to 2024, SDG&E had 8 overhead repair notifications that were completed or pending completion past SDG&E's scheduled due date for corrective action.	SDG&E acknowledged corrective actions for 8 orders were late and confirms 6 corrective actions have been completed in the field. 2 are in design for engineer solution and are being properly tracked.
The down guy wire supporting Pole Z2001473035 was loose.	Corrective action was completed 12/2/2024.

Items listed in your letter dated November 14th, 2024, have been addressed by SDG&E. If you have questions regarding these comments, please do not hesitate to contact myself at (619)-751-5256 or at saguila2@sdge.com or Monica Curry at (619) 694-9323 or at mcurry@sdge.com

Sincerely,
Sandra Aguilar
Team Lead - Substation & Transmission Compliance
cc. Monica Curry SDG&E, Christian Henderson SDG&E